Job Name/Location: Tag #:

Date:	For: File Resubmit
PO No.:	Approval Other
Architect:	GC:
Engr:	Mech:

Rep: (Company) (Project Manager)

ARUB072CTE4

Multi V™ IV Heat Recovery 575V





6.0 Ton Outdoor Unit

Performance:

Cooling Mode:

Nominal Capacity (Btu/h)	72,000
Power Input ¹ (kW)	4.37

Heating Mode:

Nominal Capacity (Btu/h)	81,000
Power Input¹ (kW)	5.02

Nominal Capacity is outside the scope of AHRI Standard 1230 and based on the following conditions:

Indoor: 80°F DB / 67°F WB Indoor: 70°F DB Outdoor 95°F DB Outdoor 47°F DB / 43°F WB

Electrical:

Liectificai.	
Power Supply (V/Hz/Ø)	575/60/3
MOP (A)	20
MCA (A)	13.6
Rated Amps (A)	11.3
Compressor A (A)	9.2
Compressor B (A)	-
Fan (A)	2.1

Piping:

Refrigerant Charge (lbs)	16.9
Liquid Line (in, OD)	3/8
Vapor Line High (in, OD)	5/8
Vapor Line Low (in, OD)	3/4

Standard Features:

- •HiPOR (high pressure oil return)
- •Smart Oil Control
- Split Coil Defrost
- Night Quiet Operation
- Fault Detection and Diagnosis

Optional Accessories:

Air Guide - PRAGX2S0

Operating Range:

Cooling (°F DB)	14-122
Heating (°F WB)	-13 - 61

Unit Data:

Refrigerant Type	R410A
Refrigerant Control	EEV
Max Number of Indoor Units ²	13
Sound Pressure ³ dB(A)	58.5
Net Unit Weight (lbs)	430
Shipping Weight (lbs)	452
Communication Cable ⁴ (No. x AWG)	2 x 18
Heat Exchanger Coating	GoldFin™

Compressor:

Compressor Type	HSS DC Scroll
Compressor Quantity	1
Oil/Type	PVE/FVC68D

Fan:

Туре	Propeller
Quantity	1
Motor/Drive	Brushless Digitally Controlled/Direct
Air Flow Rate (CFM)	7,400

Notes:

- 1.For AHRI ratings, refer to the AHRI website http://www.ahridirectory.org.(will be registered) 2. The combination ratio must be between 50 - 130%.
- 3.Sound Pressure levels are tested in an anechoic chamber under ISO Standard 3745.

 4.All communication cable to be minimum 18 AWG, 2-conductor, stranded, shielded and must comply with applicable local and national code.
- 5.Nominal data is rated 0 ft above sea level, with 25 ft of refrigerant line per indoor unit and a 0 ft level difference between outdoor and indoor units. All capacities are net with a combination ratio between 95-105%.
- 6.The voltage tolerance is ± 10%.
- 7. Power wiring cable size must comply with the applicable local and national code.






ARUB072CTE4

Multi V™ IV Heat Recovery 575V 6.0 Ton Outdoor Unit



Tag #:		
Date:		
PO No.:		



	to	ote -
= Ce	olerance of ± 0.25	Alld
Center	ce of	imen
r of Gravit	± 0.25	All dimensions have
avit	'n.	hav

Note - All	Z	~	×
Note - All dimensions have tolerance of + 0.25 in.	29-5/8"	13-1/2"	17-5/8"

Center of Gravity

M4	МЗ	M2	M1	L11	L10	L9	L8	L7	16	L5	L4	L3	L2	L1	Ξ	D	V
31-3/16"	2-5/8"	7/16"	29-1/16"	3-5/16"	2-9/16"	24-3/16"	2-9/16"	2-9/16"	22-7/16"	5-3/8"	5-1/2"	3-1/8"	2-15/16"	7-1/4"	66-1/8"	29-15/16"	36-1/4"